



Unit 34, Jessops Riverside
800 Brightside Lane
Sheffield S9 2RX
Tel: 0114 256 1197
Fax: 0114 242 2440

PPM Testing and Inspection Regime for Abseil Anchors and Equipment

Equipment Covered

Abseil track suspension systems, abseil eyebolts and abseil davits.

Applicable Legislation

The testing, inspection, recording and certification of the above equipment are completed in line with the following legislation:-

- **LOLER: 2015** - Lifting Operations and Lifting Equipment Regulations
- **BS ISO 22846 : 2012** - Personal equipment for protection against falls — Rope access systems

Schedule of Requirements

LOLER : 2015 – Reg 9 Thorough examination and inspection “Period of thorough examinations” *in the case of lifting equipment for lifting persons or an accessory for lifting, at least every six months.*
:-

- Pre use checks are to be completed by the operator before commencing work each day or each shift.
- Thorough examinations – completed at six-monthly intervals.

Brief resume of works generally completed by us on the above visits

- Is a permit to work system in operation
- Is a technical file available for the installation, if not additional type testing may be required
- An annual weight test in line with 100% of the Safe Working Load of the equipment.
- Inspection of all components of the equipment will be carried out generally to the items detailed below but not restricted to these items.

1. Safety devices trolley brakes etc.
2. Eyebolts inspected and pull tested in line with BSEN 795 & 7883.
3. moving parts, e.g. travel wheels and rollers;
4. tracks
5. supporting structures and connections to the building structure, e.g. track supports and roof fixings;
6. Demountable parts.

Checks will be carried out for wear corrosion and correct operation to determine if the equipment is fit for use. Parts which are found to be worn or defective should be repaired or replaced as necessary.

Should systems not be inspected by their due date they MUST be taken out of service and not used until they have been re-certified.





Unit 34, Jessops Riverside
800 Brightside Lane
Sheffield S9 2RX
Tel: 0114 256 1197
Fax: 0114 242 2440



Access Contracting Limited T/A Access Testing: Registered in England No. 3240798.
Registered office 13-14 Flemming Court, Whistler Drive, Castleford, West Yorkshire WF10 5HW